

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513319
LIMS Reference ID: AD13319
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow Township School 2 LIW Sampling

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 15:00

Reported:

03/31/2025 15:23

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WS2-FB Lims Reference ID: AD13319-01 Matrix: Drinking Water Sampled: 03/15/25 10:22:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-SO-KIT1L Lims Reference ID: AD13319-02 Matrix: Drinking Water Sampled: 03/15/25 10:22:00									
Metals									
Lead	19.6		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-SO-KIT1L (FLUSH) Lims Reference ID: AD13319-03 Matrix: Drinking Water Sampled: 03/15/25 10:22:00									
Metals									
Lead	4.38		1	1.00	µg/L	03/25/25 13:03	03/26/25 17:52	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: WS2-SO-KIT1R Lims Reference ID: AD13319-04 Matrix: Drinking Water Sampled: 03/15/25 10:23:00									
Metals									
Lead	3.01		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-SO-KIT2 Lims Reference ID: AD13319-06 Matrix: Drinking Water Sampled: 03/15/25 10:22:00									
Metals									
Lead	1.23		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-HALL1FR Lims Reference ID: AD13319-08 Matrix: Drinking Water Sampled: 03/15/25 10:22:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-HALL1CR Lims Reference ID: AD13319-10 Matrix: Drinking Water Sampled: 03/15/25 10:24:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-HALL1CL Lims Reference ID: AD13319-12 Matrix: Drinking Water Sampled: 03/15/25 10:25:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-HALL1FL Lims Reference ID: AD13319-14 Matrix: Drinking Water Sampled: 03/15/25 10:26:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:44	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513319
LIMS Reference ID: AD13319
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow Township School 2 LIW Sampling

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 15:00

Reported:

03/31/2025 15:23

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WS2-WC-HALL2 Lims Reference ID: AD13319-16 Matrix: Drinking Water Sampled: 03/15/25 10:27:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-WC-HALL3L Lims Reference ID: AD13319-17 Matrix: Drinking Water Sampled: 03/15/25 10:27:00									
Metals									
Lead	5.93		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-HALL3R Lims Reference ID: AD13319-19 Matrix: Drinking Water Sampled: 03/15/25 10:28:00									
Metals									
Lead	4.87		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-SO-NURSE Lims Reference ID: AD13319-21 Matrix: Drinking Water Sampled: 03/15/25 10:30:00									
Metals									
Lead	1.06		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-SO-FAC Lims Reference ID: AD13319-23 Matrix: Drinking Water Sampled: 03/15/25 10:31:00									
Metals									
Lead	3.03		1	1.00	µg/L	03/21/25 15:29	03/25/25 08:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-01 Lims Reference ID: AD13319-25 Matrix: Drinking Water Sampled: 03/15/25 10:32:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:29	03/25/25 09:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-06 Lims Reference ID: AD13319-27 Matrix: Drinking Water Sampled: 03/15/25 10:33:00									
Metals									
Lead	2.80		1	1.00	µg/L	03/21/25 15:29	03/25/25 09:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-02 Lims Reference ID: AD13319-29 Matrix: Drinking Water Sampled: 03/15/25 10:33:00									
Metals									
Lead	2.19		1	1.00	µg/L	03/21/25 15:29	03/25/25 09:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-05 Lims Reference ID: AD13319-31 Matrix: Drinking Water Sampled: 03/15/25 10:34:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:29	03/25/25 09:09	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513319
LIMS Reference ID: AD13319
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow Township School 2 LIW Sampling

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 15:00

Reported:

03/31/2025 15:23

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WS2-DW-03 Lims Reference ID: AD13319-33 Matrix: Drinking Water Sampled: 03/15/25 10:35:00									
Metals									
Lead	1.84		1	1.00	µg/L	03/21/25 15:29	03/25/25 09:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-04 Lims Reference ID: AD13319-35 Matrix: Drinking Water Sampled: 03/15/25 10:39:00									
Metals									
Lead	5.44		1	1.00	µg/L	03/21/25 15:29	03/25/25 09:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-HALL4L Lims Reference ID: AD13319-37 Matrix: Drinking Water Sampled: 03/15/25 10:40:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:29	03/25/25 09:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-HALL4CL Lims Reference ID: AD13319-39 Matrix: Drinking Water Sampled: 03/15/25 10:41:00									
Metals									
Lead	1.56		1	1.00	µg/L	03/21/25 15:30	03/25/25 18:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-HALL4CR Lims Reference ID: AD13319-41 Matrix: Drinking Water Sampled: 03/15/25 10:37:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:30	03/25/25 18:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-HALL4FR Lims Reference ID: AD13319-43 Matrix: Drinking Water Sampled: 03/15/25 10:38:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:30	03/25/25 18:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-13 Lims Reference ID: AD13319-45 Matrix: Drinking Water Sampled: 03/15/25 10:39:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:30	03/25/25 18:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-07 Lims Reference ID: AD13319-47 Matrix: Drinking Water Sampled: 03/15/25 10:41:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:30	03/25/25 18:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-12 Lims Reference ID: AD13319-49 Matrix: Drinking Water Sampled: 03/15/25 10:42:00									
Metals									
Lead	1.54		1	1.00	µg/L	03/21/25 15:30	03/25/25 18:31	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513319
LIMS Reference ID: AD13319
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow Township School 2 LIW Sampling

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 15:00

Reported:

03/31/2025 15:23

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WS2-DW-08 Lims Reference ID: AD13319-51 Matrix: Drinking Water Sampled: 03/15/25 10:43:00									
Metals									
Lead	1.32		1	1.00	µg/L	03/21/25 15:30	03/25/25 18:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-11 Lims Reference ID: AD13319-53 Matrix: Drinking Water Sampled: 03/15/25 10:45:00									
Metals									
Lead	1.02		1	1.00	µg/L	03/21/25 15:30	03/25/25 18:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-09 Lims Reference ID: AD13319-55 Matrix: Drinking Water Sampled: 03/15/25 10:46:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:30	03/25/25 18:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS2-DW-10 Lims Reference ID: AD13319-57 Matrix: Drinking Water Sampled: 03/15/25 10:48:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 15:30	03/25/25 18:39	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513319
LIMS Reference ID: AD13319
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow Township School 2 LIW Sampling

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 15:00

Reported:

03/31/2025 15:23

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2025
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513319
LIMS Reference ID: AD13319
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow Township School 2 LIW Sampling

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 15:00

Reported:

03/31/2025 15:23

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING



Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13319

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

Report To Contact Name: James Eberts					Bill To Company: Epic Environmental Services, LLC									
Company Name: Epic Environmental Services, LLC					Attention To: James Eberts									
Street: 80 Fork Bridge Rd.					Street: 80 Fork Bridge Rd.									
City: Elmer		State/Province: NJ		Zip/Postal Code: 08318		City: Elmer		State/Province: NJ		Zip/Postal Code: 08318				
Phone : 856-205-1077			Fax : 856-205-0413			Phone: 856-205-1077			Fax: 856-205-0413					
Project Name: Winslow Township School 2 LIW Sampling					Email Results To: jeberts@epicenviro.com					Purchase Order: 25-1057				
U.S. State where Samples Collected: NJ					Number of Samples in Shipment: 58					Date of Shipment: 3/17/25				
Sample for Compliance? Yes ☒ No ☐ If yes, NPDES? ☐ Other (Specify):														
Samples Collected by: EMSL ☐ Client ☒ check one					Sampled By (Signature): 			Samples Received Chilled (Y/N)						
Standard Turnaround Time: ☒ 2 Weeks				The following TATs are subject to lab approval: ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day										
Failure to complete will hinder processing of samples				Matrix		Preservative		List Test(s) Needed						
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8 Total Lead				Field pH	Field pH Test Time	Field Temp. Deg C	Field Temp. Test Time	Comments
1 WS2-FB	☐	☒	3/15/25 1022	W	2	X								
2 WS2-SO-KIT1L	☐	☒	1022	W	2	X								
3 WS2-SO-KIT1L FLUSH	☐	☒	1022	W	2	X								
4 WS2-SO-KIT1R	☐	☒	1023	W	2	X								
5 WS2-SO-KIT1R FLUSH	☐	☒	1023	W	2	X								
Released By (Signature): 				Date & Time: 3/17/25		Received By				Date & Time				
Please indicate reporting requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Disk Deliverable ☐ Other														
Instructions or Comments: Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.														
Analyze FIRST DRAW Samples. Analyze FLUSH samples if corresponding First Draw result is above 15.5 ppb														



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13319

PHONE:

FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				Matrix	Preservative	List Test(s) Needed								Comments
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8				Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	
6 WS2-SO-KIT2	☐	☐	3/15/25- 1022	W	2									
7 WS2-SO-KIT2 FLUSH	☐	☐	1022	W	2									
8 WS2-DW-HALL1FR	☐	☐	1022	W	2									
9 WS2-DW-HALL1FR FLUSH	☐	☒	1022	W	2									
10 WS2-DW-HALL1CR	☐	☒	1024	W	2									
11 WS2-DW-HALL1CR FLUSH	☐	☒	1024	W	2									
12 WS2-DW-HALL1CL	☐	☒	1025	W	2									
13 WS2-DW-HALL1CL FLUSH	☐	☒	1025	W	2									
14 WS2-DW-HALL1FL	☐	☒	1026	W	2									
15 WS2-DW-HALL1FL FLUSH	☐	☒	1026	W	2									
16 WS2-WC-HALL2	☐	☒	1027	W	2									
17 WS2-DW-HALL3L	☐	☒	1027	W	2									
18 WS2-DW-HALL3L FLUSH	☐	☒	1028	W	2									
19 WS2-DW-HALL3R	☐	☒	1028	W	2									
20 WS2-DW-HALL3R FLUSH	☐	☒	1030	W	2									
21 WS2-SO-NURSE	☐	☒	1030	W	2									
22 WS2-SO-NURSE FLUSH	☐	☒	1031	W	2									

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13319

PHONE:

FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				Matrix	Preservative	List Test(s) Needed								Comments
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8				Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	
23			3/15/25 1031	W	2									
24			1032	W	2									
25			1032	W	2									
26		x	1032	W	2									
27		x	1033	W	2									
28		x	1033	W	2									
29		x	1033	W	2									
30		x	1034	W	2									
31		x	1034	W	2									
32		x	1034	W	2									
33		x	1035	W	2									
34		x	1035	W	2									
35		x	1039	W	2									
36		x	1039	W	2									
37		x	1040	W	2									
38		x	1040	W	2									
39		x	1041	W	2									

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13319

PHONE:

FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				Matrix	Preservative	List Test(s) Needed								Comments
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8				Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	
40 WS2-DW-HALL4CL FLUSH	☐	☐	3/11/17 1037	W	2									
41 WS2-DW-HALL4CR	☐	☐	1037	W	2									
42 WS2-DW-HALL4CR FLUSH	☐	☐	1038	W	2									
43 WS2-DW-HALL4FR	☐	☒	1038	W	2									
44 WS2-DW-HALL4FR FLUSH	☐	☒	1039	W	2									
45 WS2-DW-13	☐	☒	1039	W	2									
46 WS2-DW-13 FLUSH	☐	☒	1040	W	2									
47 WS2-DW-07	☐	☒	1041	W	2									
48 WS2-DW-07 FLUSH	☐	☒	1041	W	2									
49 WS2-DW-12	☐	☒	1042	W	2									
50 WS2-DW-12 FLUSH	☐	☒	1042	W	2									
51 WS2-DW-08	☐	☒	1043	W	2									
52 WS2-DW-08 FLUSH	☐	☒	1044	W	2									
53 WS2-DW-11	☐	☒	1045	W	2									
54 WS2-DW-11 FLUSH	☐	☒	1046	W	2									
55 WS2-DW-09	☐	☒	1046	W	2									
56 WS2-DW-09 FLUSH	☐	☒	1047	W	2									

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13319

PHONE:

FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				Matrix	Preservative	List Test(s) Needed								Comments
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8				Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	
57 WS2-DW-10	☐	☐	7/15/25 1048	W	2									
58 WS2-DW-10 FLUSH	☐	☐	↓ 1048	W	2									
	☐	☐		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									
	☐	☒		W	2									

(Lab) Received Temperature: _____ °C